

Ashburnham Board of Health Minutes Dec 6th, 2010

1. The ABOH meeting convened at 6:35 pm with the following members present. Jim Garreffo (NBOH), Patrick Durkee , Tom Flanagan(Acting Secretary), Glen Hathaway (chairman)
2. The minutes dated November 1, 2010 were approved.
3. The agenda dated December 6, 2010 was approved.
4. Reviewed correspondence
5. The Board agreed on alternative dates for meeting days in FY2012 that conflict with holidays. Monday July 4ths meeting was moved to Monday July 11, 2011. Monday Labor Day September 5ths meeting was moved to Monday September 12, 2011.
6. 6:40 PM Deline Engineering representing O'Connell, 44 High Street seeking local upgrade approval.

Variations:

1. Reduce offset of groundwater from 4ft to 3 ft.

Approved unanimously

7. Michael Murphy, 75 West Shore Drive seeking local upgrade approval.

Variations:

1. Reduction of the required 4 ft separation between the bottom of the leaching area and the high ground water. (3 ft. separation proposed)
2. Reduction of the required 12 inch separation between the tank inlet and outlet tees and high ground water. (Less than 12 inch separation proposed, all boots and pipe joints to be sealed with hydraulic cement)

Approved unanimously:

Signing and final approval pending submittal of approved plans

8. Convened at 6:59 PM

Respectfully submitted,

Tom Flanagan
Acting Secretary, ABOH