

**Town of Ashburnham  
Board of Health Minutes  
October 6, 2014**

1. The ABOH Meeting convened at 6:30 PM with the following members present Scott Sibley, Patrick Durkee, Glenn Hathaway, Tom Flanagan, Dr. John McLaughlin (6:43) and Rick Metcalf of NABOH.
2. The agenda dated Oct 6th, 2014 **VOTED and ALL APPROVED.**
3. Minutes dated Sept 8th, 2014 **VOTED and ALL APPROVED.**
4. Reviewed correspondence.
5. Septic permits approved:
  - a. 145 Tuckerman Rd. – Permit Renewal
  - b. 10 Four Winds Drive – Tank Replacement
6. 6:35pm, 93 Platts Road, Jim Krasawski extended to Nov 2014 meeting for loan update.
7. 6:40pm, 44 Bluefield Road, Lawrence Sperring, variance for off-set to leach field 10' to 5', Rick to sign-off once as build dimension has been confirmed and meets minimum of 5'. **VOTED and ALL APPROVED.**
8. 6:45pm, 12 Cobb Rd., Angel from Northland Engineers, variance to high water 4' to 3'. **VOTED and ALL APPROVED.**
9. Discussion on 73 Fitchburg Road – Update. Rick reviewed LSP and confirmed agent was properly licensed, had no documented complaints on file, the meter used was properly calibrated and is designed to detect any/all petroleum products and none were detected per LSP.
10. Discussion on 31 Main St. – Update. Rick discussed with town council the status and ABOH will draft an enforceable agreement to be added to the deed.
11. Discussion on Pipeline – Cynda Warren Joyce asked that the board review presented material to begin the education from those that oppose the installation in Ashburnham on grounds of a potential public health hazard.

The ABOH October 6, 2014 meeting adjourned at 7:55 PM.

Respectfully submitted,  
Scott Sibley  
Acting Secretary, ABOH

RECEIVED  
14 NOV 21 PM 2:16  
ASHBURNHAM TOWN CLERK