

Board of Health, Special Meeting to Approve Septic Design: 1048 Benton Hill Rd., May 12, 2017 - Minutes


Members Present: Chairperson, Gale LaBelle; Treasurer/Secretary, David Krawet

Members Absent: Assistant Chairperson, Laurel Burgwardt

Taking Minutes: Jessica Perotti

Chairperson LaBelle calls the meeting to order at 2:12 P.M. LaBelle informs Krawet they are there to discuss the approval of the Application for Disposal System Construction Permit for this property. The design was approved at the last meeting but required an **RDA (Request for Determination of Applicability)** before construction could begin. The owner of the property has requested written approval of the septic design before she will apply for the RDA. LaBelle and Krawet discuss required distances from nearby streams, neighboring wells, septic systems and property lines. Krawet made a **Motion to Approve** a 3' separation from estimated seasonal high groundwater. LaBelle seconds the Motion. In order to stay 100' from the wells, the **SAS (Soil Absorption System)** would be placed 1.3' from the neighboring property line and 17' from northwest corner of existing house. Krawet makes a **Motion to Approve** the SAS to be installed 1.3' from property line. LaBelle seconds the motion. Krawet makes a **Motion to Approve** the SAS installation to be 17' from the northwest corner of the house. LaBelle seconds the motion. With both Board Members in agreement on all 3 Motions, **Motions are approved.**

Motion to Adjourn made by Chairperson LaBelle and seconded by Krawet. **Motion approved.**
Meeting adjourned at 2:42 P.M.

The block contains two handwritten signatures in black ink. The top signature is 'Gale LaBelle' and the bottom signature is 'David Krawet'. Both are written in a cursive, flowing style.