

ISLAND WATER SOURCE, INC.

RR1 BOX 7 MVABP

23 NORTH LINE ROAD

EDGARTOWN MA 02539

Phone : (508) 693-4999 Fax : (508) 693-6186

**received**  
10-27-2010

R E C E I P T

CHOLMARK  
TOWN OF CHILMARK  
TIM CARROLL/MARINA LENT  
P. O. BOX 1195  
CHILMARK, MA 02535

Date Oct 23, 2010e 12:56 PM No. 11715 Page 1 Cust. Ref

Pmt. Ref. Sales Rep 4  
Pmt. Ref.

Item #	Description	Ordered	Unit Price	Extended
	Problems with bacteria at community center. Not in library. Chlorinated well discovered leak in water main between the well and the library. Outer pitless fitting worn through. Replaced with all stainless. Bacteria has to be an issue in the building after the storage tank.			
122	PITLESS 4" STAINLESS STEEL	1.0	168.5500	168.55
394	BRASS NIPPLE 1-1/4"x 4"	1.0	58.6500	58.65
690	BRASS NIPPLE 1/4"x CL	1.0	8.6500	8.65
191	BRASS TEE 1-1/4"	1.0	86.5300	86.53
182	STAINLESS ADAPTER MA 1-1/4	2.0	28.6500	57.30
448	SS INSERT COUPLIN	1.0	18.3500	18.35
446	BRASS CTSXMIPS 1.25"	1.0	45.7500	45.75
653	BRASS ELL 1-1/4" 90	1.0	68.6500	68.65
188	BRASS ADAPTER FE 1"	1.0	21.5600	21.56
186	STAINLESS ADAPTER MA 1"	1.0	22.3600	22.36
268	CLAMP SS 1"& 1-1/4"	16.0	5.6100	89.76
204	BRASS PLUG 1/4"	1.0	12.9500	12.95
205	BRASS PLUG 1/2"	1.0	8.1600	8.16
357	WELL CAP 4" SANITARY	1.0	58.0000	58.00
334	PVC ADAPTER MA 1"	1.0	1.9100	1.91
207	CHLORINE DISENFECTANT	3.0	8.0000	24.00
1718	LABOR DAVE WELL/PUMP/TANK	7.0	105.0000	735.00
1716	LABOR SAM WELL/PUMP/TANK	4.0	95.0000	380.00
	Discount			
252	NON INVENTORY	-1.0	186.1300	-186.13

Sub-Total : 1680.00  
Tax : 0.00  
Net Due : 1680.00  
Amt. Paid : 0.00  
Balance Due: 1680.00

*Joint Maintenance Acct.  
Community Center*  
