



December 11, 2018

Re: Notice of Variance Request, Warren Doty #62 Menemsha Crossroad, CH A.P. 26-105  
VLS&E Job No. 2300

Dear Abutter,

The Chilmark Board of Health requires that any Disposal Works Permit applicant requesting variances to local Board of Health and/or Massachusetts Title 5 regulations, must notify abutters of the project and the Board of Health hearing where the variance request will be considered. Therefore, this letter is to notify you that a Board of Health hearing will be held at the Chilmark Town Hall

**January 2, 2019 at 5:30 P.M.**

The following variances are being sought from **Chilmark Board of Health and Regulations:**

- Leaching facility to wetland separation; from 150' required – 100' proposed.

Complete copies of the plan may be examined at the Board of Health or this office. Please call the Board of Health or this office with any questions regarding this notice.

Sincerely,

Reid G. Silva, PE/ PLS  
Professional Engineer  
Professional Land Surveyor

