

Board of Health Minutes
February 20, 2018

The meeting opened at 7:15 p.m. with Ms. Amodei, Ms. Moeller and Mr. Parkin present.

The minutes of the meeting of February 6th were approved as written.

384 Forest Street

The Board reviewed and approved the septic plan and signed the septic permit.

30 Sky Top Lane

A 5 foot well variance from the property line was approved by the Board in order for the well to meet the offset of 100 feet from the septic system on the adjacent lot. They reviewed the plan and approved it. The septic permit was signed by the Board.

29 Sky Top Lane

The Board reviewed and approved the septic plan and signed the septic permit.

27 French Ct.

The Board approved the plan with the requirement that the expansion area needs to be on the asbuilt showing the limit of fill needed for the system.

Other Business:

The Board would like a link added to the Board of Health section of the town website informing people why it is not advised to install a garbage grinder if you use a septic system.

The meeting adjourned at 8:10 p.m.

