

Maine Thermal Energy Services audits comprehensive, Eastport summer 2014

#	cfm50 in	cfm50 out	% improved	air flow reduction cfm50	equivalent window sq. in.
1	3,385	3,125	7.7%	260	17.7
2	2,535	2,275	10.3%	260	15.1
3	5,550	4,190	24.5%	1,360	20.5
4	9,800	9,200	6.1%	600	30.3
5	5,950	5,150	13.4%	800	22.7
6	1,975	1,810	8.4%	165	13.5
7	5,125	4,700	8.3%	425	21.7
8	3,185	2,800	12.1%	385	16.7
9	4,100	3,650	11.0%	450	19.1
10	4,150	3,688	11.1%	462	19.2
11	1,884	1,550	17.7%	334	12.4
12	2,200	1,975	10.2%	225	14.1
13	980	920	6.1%	60	9.6
14	5,050	4,650	7.9%	400	21.6
15	3,310	3,050	7.9%	260	17.5
16	3,410	3,010	11.7%	400	17.3
17	2,750	1,860	32.4%	890	13.6
18	5,610	4,960	11.6%	650	22.3
19	3,210	2,960	7.8%	250	17.2
20	3,050	2,100	31.1%	950	14.5
21	3,020	2,825	6.5%	195	16.8
22	4,225	3,380	20.0%	845	18.4
23	1,910	1,780	6.8%	130	13.3
24	4,275	3,990	6.7%	285	20.0
25	1,640	1,640	0.0%	0	12.8
26	3,910	2,935	24.9%	975	17.1
27	4,510	4,080	9.5%	430	20.2
AVG:	3,730 air cf/m	3,269 air cf/m	12.3%	461 air cf/m	18 sq. in. opening