

**BOARD OF HEALTH  
MEETING MINUTES  
Wednesday, June 15, 2016**

**ATTENDEES: Robert O'Hanley, Chairman  
Douglas Gelina, Member  
Deborah Ketchen, Health Agent  
Anita Wright, RN, Public Health Nurse  
Lori Bentsen, Administrative Asst.**

Meeting Open: 5:00 PM

**AGENDA:**

138 Washington St., 5 variance requests. Jim Scanlan, Scanlan Engineering, Georgetown, MA was present to discuss the variances with the Board.

1. O'Hanley made a motion to approve 310CMR15.212(1), REQUIRED: 4 feet to ESHGW, PROVIDED: 2 feet to ESHGW with Presby Enviro-Septic Pipe. Gelina seconded and it was a unanimous vote.
2. O'Hanley made a motion to approve 310CMR15.104, REQUIRED: Percolation test in leach area, PROVIDED: Soil analysis UMass lab. Gelina seconded and it was a unanimous vote.
3. O'Hanley made a motion to approve 310CMR15.102(2), REQUIRED: A minimum of two (2) deep hole observations shall be performed in the presence of the approving authority, PROVIDED: One (1) deep hole in primary area. Gelina seconded and it was a unanimous vote.
4. O'Hanley made a motion to approve 310CMR15.227(5), REQUIRED: One (1) foot minimum separation between pipe inverts of tanks and ESHGW, PROVIDED: Have rubber boots. Gelina seconded and it was a unanimous vote.
5. O'Hanley made a motion to approve REQUIRED: Town of Groveland Regulation B-III (8), 150 Gal/Bdrm, PROVIDED: Title 5 110 Gal/Bdrm. Gelina seconded and it was a unanimous vote.

The health agent told the Board that she was called to a residence by the Fire Dept. Ketchen told the Board that the Police Dept. initially received the 911 call for domestic violence. Ketchen told the Board that she observed hoarding issues and she has been working with the homeowner to clean the home since her release

Board of Health Meeting Minutes  
June 15, 2016 – Page 2

from the hospital. The health agent told the Board that she would keep them informed on the progress.

Meeting adjourned 6:10 PM

Next scheduled Board of Health meeting to be announced.