

CONSERVATION COMMISSION
11 August 2014 at 3:00 PM
Site Visits

In attendance:

Members: Ed Chamberlain (Chair), Doug McIlroy

Staff: Vicki Smith

Others: Laurie Greenberg, Jim Barry

Visit to 7 Fern Lane

Ed disclosed that his wife, Ingrid, and Laurie Greenberg had been good friends. Doug and Ed met with Laurie Greenberg to review her septic system replacement plans. The southwest corner of the existing leach field looked damper than the rest of the area. Laurie explained that there was no blockage in the system and that the d-box was intact and level.

Ed and Doug ascertained that given the location of the well and wetlands, the proposed location made the most sense. The plans call for fill to raise the system and for the garbage disposal to be removed. In Note 2 of the construction sequence the references to “hay” should be replaced with “straw”. There was discussion about how the leach field would be accessed. Laurie said that the installer would go directly from the door yard down the slope to the leach bed.

Visit to 115 Ruddsboro Road

Because Jim Barry has worked for Doug, he did not feel comfortable reviewing Jim’s project. Ed met with Jim and reviewed the new septic system layout relative to the wet areas. The proposed location seemed appropriate given the wet areas, well location and terrain. Tom Otterman, the designer, has already submitted a silt fence detail. Ed asked that a construction sequence be provided as well.

Respectfully Submitted,

Vicki Smith, Scribe