



Town of Northborough

Board of Health

63 Main Street
Northborough, MA 01532-1994
Office (508) 393-5009 Fax (508) 393-3130

Members Present: Chairman Glenn French
Deirdre O'Connor
Dilip Jain
Jamie Terry, Board of Health Agent

The Board of Health held an emergency meeting on Wednesday, March 24, 2010, in Conference Room B of the Northborough Town offices. The meeting was called to order at 7:00 PM by Chairman Glenn French.

Michael Sullivan of Connorstone Engineering appeared before the Board tonight regarding 88 Howard Street. The current septic system is in total failure and in need of repair and they are seeking three variances from Local BOH regulations. The first variance request is from Groundwater offset (4' required, 3' provided), the second variance request will allow 4 feet of cover over tank and pump chamber, the third variance request will allow perc results based on sieve analysis due to saturated conditions. Ms. Terry and the Board discussed how the leach field is vented allowing oxygen in to treat the system. Chairman Glenn French made a motion to allow all three variance requests – Dilip Jain seconded the motion and the vote was unanimous.

Michael Sullivan of Connorstone Engineering also appeared before the Board tonight regarding 127 Bartlett Street. They are seeking a variance from Local BOH regulations to allow greater than 3' of cover over tanks. Mr. Sullivan reports that due to existing conditions at the residence, the plumbing cannot be moved. Ms. Terry and the Board discussed how the leach field is vented allowing oxygen in to treat the system. Chairman Glenn French made a motion to allow the variance request – Deirdre O'Connor seconded the motion and the vote was unanimous.

The next Board of Health meeting is scheduled for April 14, 2010 at 7:00 pm.

The meeting was adjourned at 7:30 pm.

Respectfully submitted,

Sarah Roach