



### SOIL EVALUATION & PERC RESULTS

DEPTH	HORIZON	TEXTURE	COLOR	MOTTLING	OTHER
0-6"	Ao	SL	10 YR 3/2	-	ORGANIC
6-30"	B	LS	10 YR 5/6	-	-
30-120"	C	F-MS	2.5 Y 6/382	60" 7.5 YR 5/8	STRATIFIED
OBSERVED GROUND WATER: NO STANDING, NO WEEPING					
ESTIMATED HIGH GROUND WATER: 60"					
NO PERC. TEST PERFORMED					

  

DEPTH	HORIZON	TEXTURE	COLOR	MOTTLING	OTHER
0-6"	Ao	SL	10 YR 3/2	-	ORGANIC
6-30"	B	LS	10 YR 5/6	-	-
30-120"	C	F-MS	2.5 Y 6/382	60" 7.5 YR 5/8	STRATIFIED
OBSERVED GROUND WATER: NO STANDING, NO WEEPING					
ESTIMATED HIGH GROUND WATER: 60"					
NO PERC. TEST PERFORMED					

  

DEPTH	HORIZON	TEXTURE	COLOR	MOTTLING	OTHER
0-6"	Ao	SL	10 YR 3/2	-	ORGANIC
6-30"	B	LS	10 YR 5/6	-	-
30-120"	C	F-MS	2.5 Y 6/382	54" 7.5 YR 5/8	STRATIFIED
OBSERVED GROUND WATER: NO STANDING, NO WEEPING					
ESTIMATED HIGH GROUND WATER: 54"					
PERC. RATE @ 38" = < 2 MPI					

### SEPTIC SYSTEM DESIGN & NOI PLAN

"BANNA ESTATES"  
 #8 HAYLEE COURT, SEEKONK, MA. 02771  
 AP 20 LOT 649 (SUBDIVISION LOT 40)

APPLICANT: ALMEIDA CONTRACTING CORP.  
 #6 BRAYTON WOODS DRIVE, REHOBOTH, MA 02769

JOB # 06-050-40A    SCALE: 1"=20'    DESIGN BY: MSF    DATE: MARCH 30, 2009

Revised:

PROFESSIONAL ENGINEERS AND LAND SURVEYORS  
 INSITE PROFESSIONAL COMPLEX, SUITE 1  
 1539 FALL RIVER AVENUE  
 SEEKONK, MA 02771  
 PHONE: (508) 336-4500  
 FAX: (508) 336-4558

SHEET 1 OF 1