TEST PIT NO 1
EXIST. GR. EL. 17.5

TEST PIT NO 2
EXIST. GR. EL 17.3



PERC RATE 2 MPI

TEST PIT NO 3
EXIST GR EL 16.7



PERC RATE 2 MPI



TYPICAL LEACHING TRENCH
SCALE: 1"=4'



100 YEAR FLOOD PLAIN
ELEV. 14.00

STAKED HAY BALES TO REMAIN IN PLACE UNTIL LOAM & SEED HAS STABILIZED.

RUNNINS RIVER
CITY OF EAST PROVIDENCE
TOWN OF SEEKONK

EXISTING SLOPE TO REMAIN NATURAL

BENCH MARK
TOP OF HEADWALL
ELEV 16.93
(DISC) M.S.L.

INV = 16.99

DUMPED STONE RIP-RAP

ONE WAY SIGN

LOAM & SEED

PAVED SWALE

PIT. CONCRETE

4" SOLID YELLOW

7.5' x 14' WIDE BOX CULVERT

DO NOT ENTER SIGN

DRIVE UP WINDOW

F.F. EL. 21.00

H/C

H/C RAMP

PROPOSED WATER

LEACHING PIT #3

GREASE TRAP (TOP TANK = 19.40)

SEPTIC TANK (TOP TANK = 19.40)

LOAM & SEED

LEACHING PIT #1 W/ 36" SUMP

12" INV = 15.00

12" PVC SCH. 40

12" INV = 15.25

SIGN (NO LEFT TURN)

U SHAPED VENT PIPE

3" PITCH

LANDSCAPED AREA

HIGHWAY LINE

TEST PIT 1

4" PERF PIPE

1 SET #2

"D" BOX

CONC. BUMPER (TYP.)

T.C. 20.12

T.C. 20.26

T.C. 19.74

T.C. 18.80

EXIST. CURB

PAVED SWALE

HIGHLAND AVE (80' WIDE) U.S. ROUTE 6

EDGE OF PVMT.

EXIST. 18" V.C. DRAIN

900' TO EXIST 6" WATER

VICTORIA SHORE CO. LTD.

SEWAGE DISPOSAL DESIGN DATA

RESTAURANT. 36 SEATS @ 35 G.P.D. =
1260 GAL + 50% = 1890 G.P.D.
USE TRENCHES: 3 LINES 85' LONG
6' APART (12" DEEP)

SEPTIC TANK 150% x 1890 = 2835
USE 1000 GAL GREASE TRAP (ROTONDO GT 6x6-7)
AND 2000 GAL SEPTIC TANK (ROTONDO ST 5x10-2)

NOTE: RAISE COVER ON GREASE TRAP AND SEPTIC TANK TO GRADE W/ C.I. FRAME & COVER

ALL SOLID PIPE TO BE 4" P.V.C. SCHEDULE 40.

INVERTS

A	17.50	(END TRENCH)
B	17.90	(OUT "D" BOX)
C	18.15	(INTO "D" BOX)
D	18.30	(OUT S. TANK)
E	18.55	(INTO S. TANK)
F	18.55	(INTO S. TANK)
G	18.65	(OUT G. TRAP)
H	18.90	(INTO G. TRAP)
I	19.00	(OUT BLDG)
J	18.65	(OUT BLDG)



SECTION A-A
SCALE: HORIZ 1"=8'
VERT 1"=8'

NOTE:
ALL AREAS DISTURBED BY EXCAVATION TO BE LOAMED AND SEEDED. (6" DEEP)

COMMONWEALTH OF MASSACHUSETTS
ANTHONY A CAPUTO
No. 29[illegible]
REGISTERED LAND SURVEYOR

EXHIBIT A

69-76

RS PLAT 8 LOT 138
.7 ACRES
HIGHWAY BUSINESS

PARKING SCHEDULE
T: (36 SEATS) @ 1 SPACE/3 SEATS = 12 SPACES
)HC 1 SPACE/2 EMPLOYEES = 3 SPACES
TOTAL = 15 SPACES
ED: 19 REGULAR & 2 HANDICAP = 21 SPACES

IGHTING TO BE IN ACCORDANCE WITH
.3.8 OF THE ZONING BY-LAWS OF
OF SEEKONK

COMMONWEALTH OF MASSACHUSETTS
ROBERT W. [illegible]
No. 27[illegible]
REGISTERED PROFESSIONAL ENGINEER

SITE PLAN
FOR
BESS EATON DONUTS
SEEKONK, MASS.

CAPUTO AND WICK LTD.
1150 PAWTUCKET AVE.
RUMFORD, R.I. 02916
401-434-8880

DATE
APRIL 84

SHEET
1 OF 1