


NO.	DESCRIPTION	DATE	BY
1	REV. NEW RTNG WALL TO PRECAST MEDIAN BARR	4-14-89	DRA
2	CHG. RETAINING WALL DIM. IN SECT. A-A	4-21-89	DRA




**PLAN VIEW**

SCALE: 1 IN = 5 FT

**ELEVATION VIEW**

SCALE: 1 IN = 5 FT



**LEGEND:**

- NEW 100% 3/4" CRUSHED STONE
- NEW BANK - RUN GRAVEL
- NEW GROUND GRID (BY OTHERS)
- 6" GRAVEL BEDDING BLANKET
- NEW AMOCO 1199 EROSION CONTROL FABRIC

**SECTION A - A**

NOT TO SCALE

**GENERAL NOTES**

- CONTRACTOR TO EXCAVATE EXISTING MATERIAL FROM SLOPED AREA AS SHOWN ON SHEETS #1 & #2 OF THIS DRAWING.
- CONTRACTOR TO INSTALL APPROX. 12 EA. NEW OWNER-FURNISHED PRE-CAST MEDIAN BARRIER RETAINING WALL PER SECTION A-A.
- CONTRACTOR TO FURNISH AND INSTALL TWO (2) NEW PRE-CAST CONCRETE STEPS (WITH SUPPORT BRACKETS AND ANCHORING BOLTS).
- CONTRACTOR TO DRILL AND INSTALL SUPPORT BRACKETS INTO ABUTTING PRE-CAST MEDIAN BARRIER RETAINING WALL.
- CONTRACTOR TO FURNISH AND INSTALL NEW BANK-RUN GRAVEL AND NEW CRUSHED STONE PER SECTION A-A, SHEETS #3 & #4 OF THIS DRAWING AND SPECIFICATIONS.
- CONTRACTOR TO COMPACT GRAVEL WITH VIBRATORY COMPACTOR BEFORE INSTALLING NEW AMOCO 1199 EROSION CONTROL FABRIC.
- CONTRACTOR TO FURNISH AND INSTALL NEW FILTER MATERIAL PER SECTION A-A AND SPECIFICATIONS.
- NEW PRE-CAST MEDIAN BARRIER RETAINING WALL TO BE APPROX. 132 FEET LONG.
- EACH NEW PRE-CAST MEDIAN BARRIER TO BE 10 FEET LONG WITH AN OVERALL HEIGHT OF 3 FEET 9 INCHES.
- CONTRACTOR WILL NOT USE ANY EXCAVATING ROCK, BOULDERS, TREES, ROOTS, DEBRIS, OR ORGANIC MATERIAL AS FILL FOR ANY AREA SHOWN ON THIS DRAWING.
- CONTRACTOR WILL REMOVE ALL SAID DEBRIS OFF AND AWAY FROM SITE TO AN AREA OF THE CONTRACTOR'S CHOICE.

**REVISED**

BY DATE 4-21-89

INVESTED IN THE FUTURE

**Eastern Utilities**  
EUA Service

PROJECT: BLACKSTONE JUNCTION  
DRAWN BY: DAC  
CHECKED BY:

ENGINEERING DEPARTMENT  
NEW RETAINING WALL

DATE: 4-5-89  
DRAWING NUMBER: 16366  
SHEET: 5 OF 5

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8