



SOIL DATA

SOIL TESTS PERFORMED 3/24/2004 BY JAMES E. MILLER PE AND WITNESSED BY HAROLD CHENEVERT OF THE SEEKONK BOARD OF HEALTH

TEST PIT 1	TEST PIT 2
84.5 - 0 A LOAMY SAND 10 YR 3/3 83.5 - 12"	84.7 - 0 A LOAMY SAND 10 YR 3/3 83.7 - 12"
B MED FINE SAND 10 YR 5/6 82.5 - 24"	B MED FINE SAND 10 YR 5/6 82.7 - 24"
C FINE SAND 10 YR 6/3 76.5 - 96"	C FINE SAND 10 YR 6/3 76.7 - 96"
PERC. RATE = <2 MPI PERC. DEPTH = 80.5 GW DEPTH = 79.5(60')	PERC. RATE = PERC. DEPTH = G.W. DEPTH = 79.7(60')

PROPOSED SEWAGE DISPOSAL SYSTEM

LOCATION: LOT 1 BROWN AVE. SEEKONK, MA

APPLICANT: J.J. CARDOSI, INC. 69-452
28 BOSTON ST
E. PROV., RI 02914

PREPARED BY: MILLER ENGINEERING
21 BROOK STREET
SEEKONK, MA (508) 761-7790
03/24/04

REVISED: 7/21/04 ADD WELL / ABUTTERS S AS

CHECKED:

03-042