



CITY OF TORRINGTON

Addendum # 1

ADDENDUM 1 HAS BEEN ISSUED PERTAINING TO QUESTIONS PRESENTED AT WALK- THRU FOR THIS PROJECT ON SEPTEMBER 22, 2015 AT 10:00 AM

BID #CSU-023-093015 DATA CLOSET COOLING SYSTEM UPGRADE

Bid opening: **September 30, 2015** Time: **11:00 AM** Location: **City Hall, 140 Main Street, Room 206, Torrington, CT**

Submit signed addenda with bid.

The City of Torrington reserves the right to accept or reject any or all bids or any portion thereof, to waive technicalities, and to award the contract as will best serve the public interest.

Dated in Torrington: September 24, 2015

Purchasing Agent _____
Pennie Zucco

Bid Submitted By: _____

Signature _____

Name of Company _____

Title _____

Address _____

Date _____

**ADDENDUM 1
HAS BEEN ISSUED
PERTAINING TO QUESTIONS PRESENTED
AT WALK-THRU
FOR THIS PROJECT ON
SEPTEMBER 22, 2015 AT 10:00 AM**



VAN ZELM HEYWOOD & SHADFORD, INC.
10 TALCOTT NOTCH FARMINGTON, CT 06032-1800
P:(860) 284-5064 F:(860) 284-5098

ADDENDUM #1

Issue Date: 09/24/15

Bid #: CSU-023-093015

Project Name: DATA CLOSET COOLING SYSTEM UPGRADE

GENERAL:

Modifications described herein as Addendum items supersede specific parts of the Contract Documents for the above-named project. All bids and the construction contract shall be based on the inclusion of these modifications.

REVISIONS TO DRAWINGS

ITEM 1: On drawing #ME-100, BASEMENT HVAC & ELECTRICAL PART PLAN, for Note#6, a pre-cast concrete pad will also be acceptable as long as the Contractor is able to properly anchor the new condensing unit to pre-cast pad.

REVISIONS TO SPECIFICATIONS

ITEM 2: In the HVAC Specifications, page 5, delete Section 1.27, SEISMIC REQUIREMENTS in its entirety.

END OF ADDENDUM#1