



CITY OF TORRINGTON

Addendum # 1

ADDENDUM 1 HAS BEEN ISSUED PERTAINING TO QUESTIONS PRESENTED AT WALK- THRU FOR THIS PROJECT ON OCTOBER 1, 2015 AT 2:00 PM

BID #CTR-023-101415 COOLING TOWER REPLACEMENT

Bid opening: **October 14, 2015** Time: **11:00 AM** Location: **City Hall, 140 Main Street, Room 206, Torrington, CT**

Submit signed addenda with bid.

The City of Torrington reserves the right to accept or reject any or all bids or any portion thereof, to waive technicalities, and to award the contract as will best serve the public interest.

Dated in Torrington: October 9, 2015

Purchasing Agent _____
Pennie Zucco

Bid Submitted By: _____

Signature _____

Name of Company _____

Title _____

Address _____

Date _____

**ADDENDUM 1
HAS BEEN ISSUED
PERTAINING TO QUESTIONS PRESENTED
AT WALK-THRU
FOR THIS PROJECT ON
OCTOBER 1, 2015 AT 2:00 PM**



VAN ZELM HEYWOOD & SHADFORD, INC.
10 TALCOTT NOTCH FARMINGTON, CT 06032-1800
P:(860) 284-5064 F:(860) 284-5098

ADDENDUM #1

Issue Date: 10/09/15

Bid #: CTR-023-101415

Project Name: COOLING TOWER REPLACEMENT

GENERAL:

Modifications described herein as Addendum items supersede specific parts of the Contract Documents for the above-named project. All bids and the construction contract shall be based on the inclusion of these modifications.

REVISIONS TO DRAWINGS

- ITEM 1: On drawing #ME-100, BASEMENT HVAC & ELECTRICAL PART PLAN, During Contractors walk thru it was noted that existing overhead BFP was not piped to floor drain. Provide required piping from BPF to adjacent floor drain next to condenser water pumps as required to bring BFP installation up to current code.
- ITEM 2: During Contractors walk, question on who is the existing building Controls contractor is: Automated Building Systems (ABS) 126 Kreiger Lane Glastonbury Ct.06033 Phone (860) 657-9257

END OF ADDENDUM#1