



CITY OF TORRINGTON
BID #EPL-016-083105
RECLAIM & PAVE SENIOR CENTER PARKING LOT
ADDENDA #1

Date of bid opening: Sept. 22, 2005 Time: 10:00AM Location: Room 109A, City Hall

Bid Bond or Certified Check required with bid: 5%

Performance Bond required if awarded bid: see "Instructions to Bidders"

Submit an original bid and a duplicate copy.

The City of Torrington reserves the right to accept or reject any or all bids or any portion thereof, to waive technicalities, and to award the contract as will best serve the public interest.

Omit State and Federal Taxes.

All prices must be F.O.B.: Destination (Torrington) unless otherwise requested.

Dated in Torrington: Sept. 12, 2005 Purchasing Agent _____
Charlene R. Antonelli, CPPB

The following Addenda #1 is issued based upon the questions, comments and advice offered during the pre-bid conference of Sept. 12, 2005.

1. Any excess materials; loam, soil, etc. shall be used to backfill the area that is located behind the new section of the parking lot and in front of the fence.
2. Sidewalks required only one 2" thick layer of finish coat asphalt.
3. Reclaim the existing parking lot material.
4. Completed parking lot to have a 1½" binder coat followed by a 1½" finish coat of asphalt.
5. "Fabric" requirement is eliminated.
6. New curbing is to be installed all around the parking lot including the "high" side of the lot.
7. The approximate dimension of the finished parking lot is 123' x 190'.
8. Bid proposals shall include the estimated number of days required to complete the job.
9. Assuming the bid is awarded on Oct. 4, 2005, include in your bid proposal the anticipated start and completion dates for this project.

ADDENDA #1 ACKNOWLEDGMENT

Company _____

Signature _____

Printed name _____

Date _____