WOLFEBORO CONSERVATION COMMISSION DREDGE & FILL MEETING

December 13, 2010

<u>Members Present:</u> Dan Coons, Chairman, Mike Hodder, Vice-Chairman, Ed Roundy, Gail Antonucci, Dave Wheeler, Lenore Clark, Randy Tetreault, Members, Sarah Silk, Alternate.

Robert Amick 20 Amley Way TM #251-25 Standard Dredge & Fill

The applicant proposes to rebuild an existing 26'x8' crib dock and add a 4'x6' extension on two posts.

Referencing the Robert Amick Standard Dredge & Fill application, TM #251-25, the files do not indicate that the dock was initially constructed prior to 1969. The Commission has no objection to issuing a rebuild permit for the applicant.

However, the Commission would prefer the dock be rebuilt to current NHDES construction standards. The Commission notes that the existing dock is a full crib dock and would prefer that provided it is being completely rebuilt, that it be reconstructed as either a pier dock or separated crib dock (multiple smaller cribs), rather than rebuilding it in the same manner it was previously constructed.