

**WOLFEBORO CONSERVATION COMMISSION
DREDGE & FILL MEETING**

January 6, 2011

Members Present: Dan Coons, Chairman, Mike Hodder, Vice-Chairman, Ed Roundy, Member.

**Brian Donnelly
78 Canopache Road
Lake Winnepesaukee
TM #251-17
Standard Dredge & Fill**

The applicant proposes to replace existing damaged deteriorating concrete retaining wall with 12"-36" diameter rip rap material backed with filter fabric and drainage stone; noting that all concrete material would be removed from wetlands jurisdiction.

The Wolfeboro Conservation Commission noted no objection to the Brian Donnelly Standard Dredge & Fill application, TM #251-17, however would prefer natural stone boulders used for the construction rather than "rip rap" and questioned whether it would be possible to vegetate the retaining wall.

**Monty Moran
80 Holden Shore Road
Lake Winnepesaukee
TM #192-7
Permit By Notification**

The applicant proposes to repair a rock retaining wall along the shoreline.

Referencing the Monty Moran Permit By Notification application, TM #192-7, the Wolfeboro Conservation Commission noted the following issues; the drawing on the plan was not to scale, there are no erosion controls noted, the photographs suggest that a portion of the shoreline is in a natural condition, suggesting that some of the proposed work may be new construction, although the application narrative indicates that it is for repair of the existing stone wall and questioned the appropriateness of the filing of the application as a PBN. The Commission also noted the application indicates that the shoreline is 100 lineal feet and that the length of the repair is also 100 lineal feet. However, the stone wall is interrupted and extends some distance landward along both portions of the stone wall; noting the plan does not indicate the exact length of wall proposed for the repair.