

**WOLFEBORO CONSERVATION COMMISSION  
DREDGE & FILL MEETING**

**March 21, 2011**

**Members Present:** Dan Coons, Chairman, Ed Roundy, Randy Tetreault, Dave Wheeler, Lenore Clark, Gail Antonucci, Members.

**Judith Peterson  
328 Sewall Road  
Lake Winnepesaukee  
TM #241-14  
Standard Dredge & Fill**

The applicant proposes the construction of an "L" piling dock to existing breakwater, two boatslips, ice piling clusters and tie off piling, install 2 seasonal boatlifts and 1 seasonal PWC lift.

**Referencing the Judith Peterson Standard Dredge & Fill application, TM #241-14, the Wolfeboro Conservation Commission questioned the basis for granting a waiver in this instance. Furthermore, it appears this location is no longer eligible for construction of a breakwater, and that this design may be prone to needing future repairs due to wave or ice damage. The Commission recommended DES inspect the site as part of your review of the application.**

**Donald Legro  
20 Keniston Island  
Lake Winnepesaukee  
TM #264-27  
Minimum Impact Expedited**

The applicant proposes to repair an existing U-shaped docking system.

**The Wolfeboro Conservation Commission noted no objection to the Donald Legro Minimum Impact Expedited application, TM #264-27.**

**Dominick Marsilio  
75 Sargents Pond Road  
Sargents Pond  
TM #98-19  
Standard Dredge & Fill**

The applicant proposes to provide a seasonal hinged pier and elevated perched single family beach with stepped access to Sargents Pond.

**The Wolfeboro Conservation Commission noted no objection to the Dominick Marsilio Standard Dredge & Fill application, TM #98-19.**

Thomas Bell  
3 Ians Way, Littlest Mud Island  
Lake Winnepesaukee  
TM #265-25  
Standard Dredge & Fill

The applicant proposes to reconstruct the existing boathouse, provide a perched beach with steps to the water and seasonal dock with concrete pad.

**The Wolfeboro Conservation Commission noted no objection to the Thomas Bell Standard Dredge & Fill application, TM #265-25, however, requests DES to review the construction of the seasonal dock to determine whether it would have an impact on the loon nesting area.**

280 South Main Street, LLC  
280 South Main Street  
Crescent Lake  
TM #231-82  
Standard Dredge & Fill

The applicant proposes driveway and drainage upgrades and the removal of pavement surrounding wetlands.

**The Wolfeboro Conservation Commission noted no objection to the proposed drainage upgrades for the 280 South Main Street, LLC Standard Dredge & Fill application, TM #231-82, however, the application appears incomplete and although there may be other areas incomplete, the Commission noted that the plan was not stamped, wetland delineation report was not included, the "20 questions" were not addressed, there was no construction sequence and erosion controls were not addressed.**